

Potential of *Champereia manillana* Shoots Extract as Coagulant for Drinking Water Treatment

Aweng, E.R.¹, Jessuta, J.¹, Prawit, K.² and Liyana, A.A.³

¹Faculty of Earth Science

Universiti Malaysia Kelantan,

Locked Bag No 100, 17600 Jeli, Kelantan, MALAYSIA

Tel.:+019-9830619, E-mail: aweng@umk.edu.my

²Faculty of Science and Technology,

Price of Songkla University,

Pattani, Thailand

³Centre for Language Studies and Generic Development

Universiti Malaysia Kelantan Bachok Campus,

Locked Bag No 1, 16300 Bachok, Kelantan, MALAYSIA

ABSTRACT

The usage of alum-based coagulant in drinking water treatment process caused residues in completed drinking water treatment, which eventually supplied to consumers. This poses possible risk to their health. Furthermore, alum-based coagulant is expensive. Due to the risk and cost of using alum-based coagulant, natural coagulants which are environmental friendly, safe and cost effective, are needed. A plant-derived coagulant was successfully extracted from *Champereia manillana* by using physical extraction method. This study was intended to explore the effectiveness and optimum dosages of *C. manillana* needed for turbidity and heavy metals removal in surface water sources. Flavonoids and tannin are coagulating agent which are naturally present in *C. manillana* shoots and they are responsible for turbidity and heavy metals removal in water. Three types of heavy metals and three level of turbidity were chosen for this study. The experiment was performed with crude extracts of *C. manillana* with different dosage. Results demonstrated that the best and optimum turbidity removal is observed in low and moderate turbid water sample (5 – 50 NTU) up to 62.9 % at 2.0 mg/L of extract *C. manillana* shoots. However, there were no significant removal in Cuprum, Ferum and Manganese. It could be concluded that, *C. manillana* shoot extract has the ability to remove suspended solid in water, hence it has a great potential to replace chemical coagulant in drinking water treatment. Furthermore, *C. manillana*. shoots extract is much cheaper as compared to chemicals coagulant. Usually people do not have the option to use water provided by the Government treated with chemicals that are harmful to health. With the use of water that has been treated with these chemicals will cause them vulnerable to many diseases and at the same time they have to spend hundreds or even thousands of ringgit a month for health care for their families. But with this discovery, people can treat water for their own use by using the resources that are around them, in a way that *C. manillana* shoots will be dried and pounded until fine and pour into a bucket of water, then stir it and leave for about half an hour or until it is settle down to the bottom of the bucket and the water is safe to use. This way they no longer have to spend money for health care as a result of use water treated with chemicals by substituting them with natural material and thus the *C. manillana* shoots may indirectly reduce poverty among the mainly rural society.

Key words: *Champereia manillana*, turbidity, ferum, cuprum, manganese, coagulant, alum

INTRODUCTION

Apparently, aluminium and ferrous or ferric salts are used in drinking water treatment as chemical coagulants to reduce the suspended solids and turbidity in raw water. Usually people do not have the option to use water provided by the Government treated with chemicals that are harmful to health. With the use of water that has been treated with these chemicals will cause them vulnerable to many diseases and at the same time they have to spend hundreds or even thousands of ringgit a month for health care for their families. According to the Malaysia Drinking Water Quality Standard, recommendations for aluminium levels in treated drinking water should not exceed 0.2 mg/L (Ministry of Health Malaysia, 2010) (**Table 1**). According to Driscoll and Letterman (1988), about 11% of the aluminium (Al) input during treatment process remains in the treated water as residual Al and distributed through piping system without any significant loss. From there, another problem has attributed to increase alum concentration where the products of alum hydrolysis are deposited on pipe walls, which decreases its capacity. Recent studies have shown that the dose of Al contained in drinking water is high, which is 0.5 mg/L and proven that high dosage of Al in drinking water could pose health risk in some cases, whereas in some worse cases, evidence points out that Al could increase the risk of Alzheimer's disease (McLachlan *et al.*, 1996). Crapper and Boni (1980) made an observation on the relationship between Al and both Alzheimer's disease and dialysis encephalopathy in humans and it was proven that kidney dialysis patients are suffering from dementia due to Al concentration of 80 microgram per litre contained in their dialysis fluid (Srinivasan *et al.*, 1999).

The level of Al intake from drinking water varies with Al level in raw water and dose of Al coagulants used in water treatment process. Various physicochemical and mineralogical factors can also significantly affect the concentration of Al in natural water. Intake of Al via food and water is unavoidable yet 5% of the total intake is from drinking water and the major part (5mg/day) of total intake comes from food and its additives (Tomperi *et al.*, 2013). Hence, it is important to minimize the amount of residual aluminium in drinking water to ensure safe drinking water for locals. Thus, the urge to replace Al salts with sources from

natural products have been raised in order to minimize the effect of the A1 residual in the treated water which results in high accumulation of turbidity and some health effects on consumers. In order to facilitate this problem, this study was proposed to determine the potential of *Champereia manillana* shoots (**Figure 1**) extracts to be used as coagulant to remove suspended solids and some heavy metals in drinking water treatment. *C. manillana* comes from Opiliaceae family and it is well known in local folklore for their medicinal value. The tree is easily propagated via sowing seeds or stem cuttings. Locally it is called "Cemperai", "Makmor" and "Dok dek". In medical aspect, *C. manillana* able to cure headaches, ulcer, splenomegaly, rheumatism, abscess, fever, and inflamed gums. Apart from that, the young shoots and leaves of *C. manillana* are used in preparation of vegetable soups and other traditional cooking as culinary among Malaysian folks (Arbain, 2008). Concerning these practices, the extract of this plant as coagulant is believed to have high potential in drinking water treatment to replace the current conventional coagulants due to its ability in removing toxins. Moreover, this method seems to be inexpensive, environmental friendly as well as an effective agent in drinking water treatment, especially in removing heavy metal and suspended solids (Yap, 2013).

Table 1.0: Drinking Water Quality Standard by Ministry of Health Malaysia, 2010

Parameter	Raw water (mg/L)		Treated Water (mg/L)	
	Min	Max	Min	Max
Turbidity	0	1000	0	5
Ferum/Iron	0.00000	1.00000	0.00000	0.30000
Manganese	0.00000	0.20000	0.00000	0.10000
Cuprum/ Copper	0.00000	1.00000	0.00000	1.00000



Figure 1.0: The leaves and fruits of *C. manillana*

The use of natural plants as natural coagulants in clarifying turbidity of water has been a common practice since ancient times. Some of the common phytochemical compounds found in plants, for instance tannins, flavonoids; oil and protein are responsible for coagulation mechanism involved in water clarification. Direct coagulation of *C. manillana* as a coagulant appeared to be effective in clarifying turbidity, coagulating suspended solids and removing heavy metals. Flavonoids are an important group of polyphenols, widely distributed among the plant floras, which has benzene ring in its structure. These compounds function as antioxidants or free radicle scavenger. The common types of flavonoid present in nearly 70% of plants are quercetin, kaempferol, and quercitrin. There might be other group of flavonoids appear to be plants phytochemical compound such that flavones, dihydroflavons, flavans, flavanols, anthocyanidins, proanthocyanidins, calchones and catechin and leucoanthocyanidins (Doughari, 2009).

Other than that, tannins also play a major role in coagulation mechanism because they have feature to turn or to convert substances into leather. The properties of tannins are such as good solubility in water and alcohol, phenolic compounds of high molecular weight and found abundantly in the root, bark, stem, and outer layers of plant tissue. They are acidic in reaction and this acidic reaction is attributed to the presence of carboxylic group. They do form complexes with

proteins, carbohydrates, gelatine and alkaloids, which are associated to formation of agglomeration, resulting in coagulation.

MATERIALS AND METHODS

Good quality shoots of *C. manillana* (**Figure 2**) were collected randomly from Tanah Merah, Kelantan, Malaysia. The collected shoots of *C.manillana* were thoroughly washed using distilled water before drying. After drying in oven for two days at temperature of 50 °C, the leaves were grounded using grinder in the laboratory. The grounded material was sieved through 0.4 mm size sieve and the particles smaller than 0.4 mm size sieve was used for crude extraction process. For the preparation of crude extract part, 1.0 g of *C.manillana* was added into 1000 ml of distilled water and then stirred by using magnetic stirrer for 60 minutes and the mixture was left for 20 minutes to settle down and after that 0.95 mm filter paper was used to filter the mixture so as to remove solid particles.



Figure 2.0: *C. manillana* shoots

Jar-test was performed in four (4) cleaned Biological Oxygen Demand (BOD) bottles. Each bottle was added with 300mL surface water sample and then different concentrations of *C.manillana* crude extract; 0.0mL, 2.0mL, 4.0mL and 6.0mL were added. The standard procedure implies 3 minutes of rapid mixing (200 rpm) in the incubator shaker at 21°C temperature followed by 30 minutes of slow mixing (50 rpm) for flocculation. The treated water was allowed to settle for 20 minutes and 100 ml of the sample was taken from the top of each BOD bottle to be measure and analysed for turbidity, iron, manganese and cuprum. Jar test was conducted by adding different dosage of concoction of the two crude plant extract to the 250ml of prepared water samples. The test was done to determine optimum dosage and proportion needed to prepare the efficient coagulant in removing Fe, Mn, Cu, and turbidity as well. The water sample with certain concentration of heavy metals and turbid samples were analysed before and after jar test. Atomic Absorption Spectrophotometer (AAS) was used to identify the concentration of heavy metals, whereas, Turbidimeter Hanna Model 2100P was used to identify the turbidity.

The difference in concentration of turbidity, iron, manganese and cuprum before and after treatment was used to indicate the effectiveness of *C.manillana* in reducing these parameters in raw water. Turbidity and heavy metals reduction were presented in percentage (%), according to Yap (2013):

$$\text{Biosorbent removal (\%)} = [(C_i - C_a) / (C_i)] \times 100$$

Where: C_i – initial concentration of heavy metals before treatment
(mg/L)

C_a - concentration of heavy metals after treatment (mg/L)

People can treat water for their own use by using the resources that are around them, in a way that *C. manillana* shoots will be dried and pounded until fine and pour into a bucket of water, then stir it and leave for about half an hour or until it is settle down to the bottom of the bucket and the water is safe to use.

RESULTS AND DISCUSSION

Turbidity Removal

Figure 3.0 and Table 2.0 show the reduction of turbidity with initial turbidity of 691.5 NTU and after treated with *C. manillana* crude extract with 2.0 mg/L, 4.0 mg/L and 6.0 mg/L respectively. The highest reduction was recorded at 2.0 mg/L concentrations of *C. manillana* with 0.12 % reduction. It could be concluded that 2 mg/L, 4 mg/L and 6 mg/L of *C. manillana* have no significant difference in removal of turbidity in highest turbidity water ($P>0.05$).

Table 2.0: Turbidity concentration after treated with *C. manillana* crude extract for 500-700 NTU water sample

Initial Turbidity (Before treatment)	Dosage of crude extracts (mg/L)	Residual Turbidity (NTU) (After treatment)
691.5 NTU	0.0	691.5
	2.0	690.7
	4.0	691.5
	6.0	691.5




Figure 3.0: Concentration of turbidity with initial turbidity 691.5 NTU treated with different dosages of *C.manillana* crude extract

Figure 3.1 and Table 2.1 show the results of coagulation mechanism study on moderate turbidity water with initial turbidity of 48.8 NTU, using *C.manillana*

crude extract to test the effectiveness of the coagulant in turbidity removal. Based on the results obtained, rapid reduction in turbidity to 20.37 NTU at 2.0 mg/L crude extract with 58.3% reduction ($P < 0.05$) and after that slowly decreased to 19.67 NTU at 6.0 mg/L with the maximum rate of removal up to 59.7 %.

Table 2.1: Turbidity concentration after treated with *C. manillana* crude extract for 30-50 NTU water sample

Initial Turbidity (Before treatment)	Dosage of crude extracts (mg/L)	Residual Turbidity (NTU) (After treatment)
48.8 NTU	0.0	48.70
	2.0	20.37
	4.0	20.73
	6.0	19.67




Figure 3.1: Concentration of turbidity with initial turbidity 48.8 NTU treated with different dosages of *C.manillana* crude extracts

Figure 3.2 and Table 2.2 show the reduction rate of turbidity with initial concentration of 14.7 NTU and after treated with *C.manillana* crude extract. It was seen that, significant reduction of turbidity ($P < 0.05$) 62.9% at 2.0 mg/L crude extract were recorded. The turbidity concentrations slowly decreased with the dosage of 4.0 mg/L and 6.0 mg/L with the maximum reduction rate of 66.6% at 6.0

mg/L crude extract respectively. However, the decrease were found to be not significant ($p>0.05$).

Table 2.2: Turbidity concentration after treated with *C.manillana* crude extract for 5.0 – 20.0 NTU water sample

Initial Turbidity (Before Treatment)	Dosage of crude extracts (mg/L)	Residual turbidity (NTU) (After Treatment)
14.7 NTU	0.0	14.50
	2.0	5.45
	4.0	5.03
	6.0	4.91




Figure 3.2: Concentration of turbidity with initial turbidity 14.7 NTU treated with different dosages of *C.manillana* crude extract

Heavy Metals Removal

Mn and Fe are natural constituents of soil and rock, also present in insoluble forms but brought into water bodies by anaerobic conditions or in the presence of carbon dioxide. Problem have been found to occur when the concentration of iron and manganese exceeds 0.3 mg/L and 0.1 mg/L respectively (Vigneswaran *et al.*, n.d.). This study focused on the effectiveness of *C.manillana* crude extract used as

coagulant in removing the Mn and Fe from water samples, which was synthesized in the laboratory.

Figure 3.3 and Table 2.3 show the iron removal efficiency through coagulation mechanism using *C.manillana* plants crude extract. It was observed that, the iron concentration decreased as the dose of coagulant increased and the elimination of iron were stabilized from 4 mg/L to 6.0 mg/L of coagulant applied. The removal rate of iron was 23.6 % after treated with 6.0 mg/L crude extract.

Table 2.3: Fe Removal

Initial concentration of Fe (mg/L) (Before Treatment)	Dosage of crude extract (mg/L)	Final concentrations of Fe (mg/L) (After treatment)
2.0 ± 0.09	0.0	1.908
	2.0	1.806
	4.0	1.699
	6.0	1.597




Figure 3.3: Fe Removal Efficiency through coagulation process using *C.manillana* Crude Extract

Figure 3.4 and Table 2.4 show the residual of Mn after treated with *C.manillana* crude extract. There was a reduction of Mn concentrations after treated with *C.manillana* crude extract but the reduction rate was significantly small (6.8%).

Although Fe and Mn showed reduction in their concentration after treatment, the values of Fe and Mn after treatment still exceeded the standard value set in the National Drinking Water for Fe and Mn which are 0.3 mg/L and 0.1 mg/L respectively.

Table 2.4: Mn Removal

Initial concentration of Mn (mg/L) (Before Treatment)	Dosage of crude extracts (mg/L)	Final concentrations of Mn (mg/L) (After treatment)
0.5±0.07	0.0	0.573
	2.0	0.571
	4.0	0.563
	6.0	0.531




Figure 3.4: Mn Removal Efficiency through coagulation process using *C.manillana* Crude Extract

Based on the test performed for the Cu, Mn and Fe contents in crude *C.manillana* extract, Cu was found to be highly present as compared to Mn and Fe with the concentrations 0.115 mg/L. This was believed to cause the concentration of Cu in treated water increase as the dosage of crude extract used increases instead of decreasing (**Figure 3.5 and Table 2.5**). Hence, the *C.manillana* crude extract is not suitable to be used as coagulant in removing Cu in water samples as it has high Cu concentrations in the plant. The high concentrations of Cu might be due to the

site which contains high Cu in the soil and substantial amount of Cu was taken in by the plant root since Cu is an essential micronutrient required in the growth of both plants and animals. In plants, Cu is an essential element for seed production, disease resistance, and regulation of water. Copper normally occurs in drinking water from Cu pipes, as well as from additives designed to control algal growth. In the soil, Cu strongly form complexes with organic compound, implying that only a small fraction of copper will be found as ionic copper, Cu(II). The high solubility of Cu will increase the pH value to 5.5. The connection between soil and water contamination and metal uptake by plants are determined by many chemical and physical soil factors as well as the physiological properties of the crops. Soils contaminated with trace metals may pose both direct and indirect threats through negative effects of metals on crop growth and yield (Wuana *et al.*, 2011).

Table 2.5: Cu Removal

Initial concentration of Cu (mg/L) (Before Treatment)	Dosage of crude extracts (mg/L)	Final concentration of Cu (mg/L) (After treatment)
1.0 ± 0.01	0.0	0.987
	2.0	1.438
	4.0	1.578
	6.0	1.558




Figure 3.5: Cu Removal Efficiency through ccoagulation process using *C.manillana* crude extract

The results show that, *C.manillana* shoot extract can remove turbidity up to 66.1% at the dosage of 6 mg/L but the optimum concentrations would be 2 mg/L with the removal rate of 62.9%. The percentage of reduction of *C.manillana* was slightly lower as compared to *Cassia alata* leaves (Aweng *et al.* 2012) and *Opuntia* spp. (Miller *et al.* 2008), where the percentage of reduction is 93.33% and 95% respectively. On the other hand, *C.manillana* shoot extract has a weak Cu, Mn and Fe removal capacity with the rate of removal ranged between 0.0 to 24%.

CONCLUSION

It could be concluded that the *C.manillana* shoot extract has a good potential to be used as natural coagulant to replace chemical coagulant in removing suspended solids in water. This way the people no longer have to spend money for health care as a result of use water treated with chemicals by substituting them with natural material and thus the use of *C. manillana* shoots as coagulant for drinking water treatment may indirectly reduce poverty among the mainly rural society. However it is in effective in eliminating heavy metals.

Acknowledgements

The authors would like to thank the management of the Faculty of Earth Science, Universiti Malaysia Kelantan and the Faculty of Science and Technology, Prince of Songkla University, Pattani, Thailand for their support in providing laboratory facilities for this project. This project would not be completed without the help and support from the management of both faculties.

References

- Aweng, E.R., A. Anwar, I., Siti Rafiqah, M.I. & Suhaimi, O. (2012). *Cassia alata* as a Potential Coagulant in Water Treatment. *Research Journal of Recent Sciences*. 1(2); 28-33.
- Arbain, M. (2008). Artikel Kenali Ulam Cemperai Mampu Ubat Ulser, Sakit Sendi. *Berita Harian*. Retrieved March 12, 2014 from <http://www.ipislam.edu.my>
- Crapper, M.D.R. & Boni, D. (1980). Aluminum in human brains disease - an overview. *Neurotoxicol.* 1; 3-16.
- Doughari, J. H. (2009). *Phytochemicals : Extraction Methods , Basic Structures and ModeofAction as Potential Chemotherapeutic Agents*. *Pytochemicals- A Global Perspective of Their Role in Nutrition and Health*.
- Driscoll, C.T. & Letterman, R.D. (1988). Chemistry and fate of Al III in treated drinking water. *J. Environ. Eng. Div., ACSE* 114 (1) 21-37.
- Ministry of Health Malaysia (2010). *Drinking Water Quality Surveillance Programme : Drinking Water Quality Standard*. Engineering Service Division, Ministry of Health Malaysia. Retrieved on March 30 from <http://kmam.moh.gov.my/public-user/drinking-water-quality-standard.html>
- Miller, S. M., Ezekiel, J. F., Vinka, O. C., James, A. S. and Julie, B. Z. (2008). Toward Understanding the Efficacy and Mechanism of *Opuntia* spp. as a Natural Coagulant for Potential Application in Water Treatment. *Environmental Science and Technology*, 42(12):4274-4279.
- McLachlan, D.R.C., Bergeron, C., Smith, J.E., Boomer, D., and Rifat, S. (1996). Risk for neuropathologically confirmed Alzheimer's disease and residual aluminium in municipal drinking water employing weighted residential histories. *Neurology*, 46, 401-405, 1996.
- Srinivasan, P. T., Viraraghavan, T., & Subramanian, K. S. (1999). *Aluminium in Drinking Water : An overview*. Faculty of Engineering, University of Regina, Regina, Canada S4S OA2; Environmental Health Directorate, Health Canada, Ottawa, Ontario, Canada K1A 0L225(1), 47–56.

- Tomperi, J., Pelo, M., & Leiviskä, K. (2013). Predicting the Residual Aluminum Level in Water Treatment Process. *Drinking Water Engineering and Science*, 6(1), 39–46.
- Vigneswaran, S., Visvanathan, C., & Sundaravadivel, M. (n.d.). Treatment Options for Removal of Specific Impurities from Water–, II. *Encyclopedia of life Support System (EOLSS)*.
- Wuana, R. A., & Okieimen, F. E. (2011). Heavy Metals in Contaminated Soils: A Review of Sources, Chemistry, Risks, and Best Available Strategies for Remediation. *ISRN Ecology*, 2011, 1–20.
- Yap, L.L.(2013). *Performance of Rambutan Seed as Iron and Manganese Removal in Groundwater*. Final Year Project. Universiti Malaysia Kelantan, Kelantan.